



Westwood # H24-30
Model 10010
1/2" x 1/2" Shafts



Westwood # H24-32
Model 10023
1/2" x 1/2" or
1/2" x 5/8" Shafts



Westwood # H24-34
Model 10034
1/2" x 5/8" or
5/8" x 5/8" Shafts



Westwood # H24-36
Model 10045
1/2" x 1/2" or
1/2" x 5/8" or
5/8" x 5/8" Shafts



The Single Spring Alternative!

Spiralink™ Coupler Cross-Reference Chart

Westwood Part #	Spiralink Model	Circulator Model		Motor		Shaft Dia.	OEM Part #	
		B & G	Armstrong	HP	Rot		B & G	Armstrong
H24-30	10010	75	S-25	1/12	CCW	1/2 x 1/2	118705 or 189110	806026
		100						
		125						
		150						
		1-1/2"	S-34	1/6				
		2"	S-35					
		2-1/2"	S-45	1/4				
		LD3	S-46	1/3				
		HD3						
		HV1"						
HV1-1/4"	H-32	1/6						
HV1-1/2"								
1"PR	H-41							
H24-32	10023	PD-35	S-55	1/2	CW	1/2 x 1/2 or 1/2 x 5/8	118473 or 118708 or 09	807436 or 806137
H24-34		10034	PD-37	S-57				
			PD-38	S-60		1		
		PD-39						
		OLD NEW						
H24-32	10023	60-1 60-11	H-51	1/4		1/2 x 1/2	118473	807436
		60-2	H-52	1/3				
		60-3 60-13	H-53	1/2				
		60-4 60-14	H-54	3/4				
H24-34	10034	60-5 60-15	H-63	1/2		1/2 x 5/8	186410 or P77237	812734
		60-6 60-16	H-64	3/4				
		60-8	H-66					
		60-17	H-65	1				
		60-19	H-67					
H24-32	10023	SERIES 1522 1S & 1T thru 17S & 17T		1/4 thru 2	1/2 X 1/2 or 1/2 x 5/8	118473 or 118709		
H24-36	10045	Taco Model	121	1/4	CCW	1/2 x 1/2 or 1/2 x 5/8 or 5/8 x 5/8	1624-053RP (Woods 3J or 4J)	
			122	1/4				
			131	1/3				
			132	1/2				
			133	3/4				
			138	1				

INFORMATION

Rotation is always determined by viewing the motor from behind, (shaft pointing away). A serviced motor may come back running the wrong direction. Make sure to check motor rotation before installing new coupling.

GUARANTEE

Spiralink™ couplers are warranted for life when correctly installed in the appropriate circulating pump. If a *Spiralink™* coupling should ever fail, simply return it to your place of purchase to receive a free replacement.